



# JEFFERSONVILLE FIRE DEPARTMENT

2204 E 10th Street Jeffersonville, Indiana 47130  
(812)285-6445 Office      Mike Moore Mayor      (812)283-3032 Fax  
Chief – Shawn Grant / Division Chief –Mike McCutcheon

A-Crew Fire Marshal–David DeArk / B-Crew Fire Marshal–John Obermeier / C-Crew Fire Marshal–Chris Kinnaird

## Fire Prevention & Safety Compliance Form

On (m) **AUGUST** (d) **16** of (y) **2022** the Jeffersonville Fire Department,  
Division of Fire Prevention and Safety inspected the business known as;

Name: **Caris College**

Address: **2780 Jefferson Centre Way Suite 103**

The inspection was conducted by the Fire Chief, and or his designated Fire Code  
Official;

Signature: David A DeArk

Printed Name: DAVID A DEARK

Title: FIRE MARSHAL

At this time the business listed above was found compliant with the standards  
set forth which the Division of Fire Prevention enforces.

The Division of Fire Prevention is to conduct inspections of the local businesses  
within our jurisdiction. The Jeffersonville Fire Department would like to thank  
your business for the efforts to maintain, protect and provide a safe facility for  
your employees and the public.

Date of Inspection: 8 / 16 / 2022 Inspector: Fire Marshal D. DeArk Time: 2:30 pm Re-inspection (Completed): \_\_\_\_\_

Name of Business: CARIS COLLEGE

Business Address: 2780 JEFFERSON CENTER WAY SUITE 103

Code references are from International Fire Code (INTFC) 2012, Indiana Fire Code (INDFC) 2014 and the current National Fire Protection Association (NFPA) applicable portions.

**\*Inspection Type-Property Identification (Assigned Address) INTFC 2012, INDFC 2014 Sec 505:**

-Address Posted & Visible from the main roadway: Pass  Fail \_\_\_\_\_  
-Address or Identifier posted on rear door where required: Pass \_\_\_\_\_ Fail \_\_\_\_\_ N/A \_\_\_\_\_

NOTE: \_\_\_\_\_  
**\*Inspection Type-Knox Box** INTFC 2012, INDFC 2014 Sec 506: Pass \_\_\_\_\_ Fail \_\_\_\_\_ N/A

NOTE: \_\_\_\_\_  
**\*Inspection Type-Fire Extinguisher(s)** INTFC 2012, INDFC 2014 Sec 906 / NFPA 10: Tagged TEST Date: Feb 2022 Pass  Fail \_\_\_\_\_

NOTE: \_\_\_\_\_  
**\*Inspection Type-Fire Alarm Panel and Protection Systems** INTFC 2012, INDFC 2014 Sec 901: Pass  Fail \_\_\_\_\_ N/A \_\_\_\_\_

NOTE: \_\_\_\_\_  
**\*Inspection Type-Exit Signage** INTFC 2012, INDFC 2014 Sec 1011:  
-Illuminated EXIT sign(s): Pass  Fail \_\_\_\_\_ N/A \_\_\_\_\_  
-Non-illuminated EXIT sign(s): Pass \_\_\_\_\_ Fail \_\_\_\_\_ N/A \_\_\_\_\_

NOTE: \_\_\_\_\_  
**\*Inspection Type-Emergency Lighting** INTFC 2012, INDFC 2014 Sec 1006: Pass  Fail \_\_\_\_\_ N/A \_\_\_\_\_

NOTE: \_\_\_\_\_  
**\*Inspection Type-EXIT Door(s)** INTFC 2012, INDFC 2014 Sec 1008: Pass  Fail \_\_\_\_\_ N/A \_\_\_\_\_

NOTE: \_\_\_\_\_  
**\*Inspection Type-(General) Electrical** INTFC 2012, INDFC 2014 Sec 605: Pass  Fail \_\_\_\_\_ N/A \_\_\_\_\_

NOTE: \_\_\_\_\_  
**\*Inspection Type-Space Heaters** INTFC 2012, INDFC 2014 Sec 605.10: Pass  Fail \_\_\_\_\_ N/A \_\_\_\_\_

NOTE: \_\_\_\_\_  
**\*Inspection Type- (Mechanical) Electrical** INTFC 2012, INDFC 2014 Sec 605:  
-Panel Box Issues: Pass  Fail \_\_\_\_\_ N/A \_\_\_\_\_  
-Panel(s) were protected and secured: Pass  Fail \_\_\_\_\_ N/A \_\_\_\_\_  
-Area was clear of combustibles: Pass  Fail \_\_\_\_\_ N/A \_\_\_\_\_

NOTE: SECURED AT TIME OF INSPECTION  
**\*Inspection Type-Commercial Cooking Hood System** INTFC 2012, INDFC 2014 Sec 609:  
- Hood Suppression System: - Tagged TEST date: N/A Pass \_\_\_\_\_ Fail \_\_\_\_\_ N/A

NOTE: \_\_\_\_\_  
**\*Inspection Type-Sprinkler System** INTFC 2012, INDFC 2014 Sec 901-904:  
-Riser, Valves, Piping and Sprinkler Head(s): -Recorded TEST date: N/A Pass \_\_\_\_\_ Fail \_\_\_\_\_ N/A

NOTE: \_\_\_\_\_  
**\*Inspection Type-Fire Department Connection (FDC)** INTFC 2012, INDFC 2014 Sec 912: -FDC Connection Access  
- FDC Protection Caps / Cover: Pass \_\_\_\_\_ Fail \_\_\_\_\_ N/A   
-PIV Secured in the OPEN Position, INTFC 2012, INDFC 2014 Sec 905: Pass \_\_\_\_\_ Fail \_\_\_\_\_ N/A

NOTE: \_\_\_\_\_  
**\*Inspection Type-Compressed (Pressurized) Cylinders** INTFC 2012, INDFC 2014 Sec 5301: Pass  Fail \_\_\_\_\_ N/A \_\_\_\_\_

NOTE: SECURED  
**\*Private Hydrant Inspection** -Recorded Test/Inspection date: \_\_\_\_\_ FD Visible Review Pass \_\_\_\_\_ Attention \_\_\_\_\_ N/A \_\_\_\_\_

**\*NOTE 1** (INTFC 2012, INDFC Sec 301:  
NOTE: \_\_\_\_\_

\*This business is requesting an Inspection Compliance Form be sent to them for their records: Yes \_\_\_\_\_ No \_\_\_\_\_

Signature of business representative or owner: [Signature]

E-mail address: msmith@cariscollege.edu Contact #: \_\_\_\_\_